

**A Mathematical Procedure For Finding Exact Hourly LOLPs
(Loss of Load Probability) For Large Electric Grids.**

by

Eugene G Preston, PE, PhD


The Austin Physics Meetup Group

Austin, Texas


June 21, 2018

The electric load of a system like ERCOT (Electric Reliability Council Of Texas) varies all the time. The load peaks in the summer months due to a large air conditioning load. Right now the summer peak demand is about 70,000 MW. The graph below shows the hourly profile of the 2010 historical year scaled to have a 70 GW peak.

ERCOT 2010 HISTORICAL PEAK DEMAND DAY WITH 24 GW WIND + 30 GW SOLAR




Generators are not 100% reliable. They are constantly failing and being repaired. An example with three generators of capacity 10, 15, and 20 MW with outage probabilities of 0.1, 0.2, and 0.3 shown as a binary tree of all combinations of 'up' and 'down' states:




The sum of units 'up' is the MW column. The probabilities are multiplied to the ends of each branch. The sum of all probabilities is 1. The MWO (megawatts outaged) is the 45 MW total minus the MW available. The MWO can be sorted in ascending order along with the branch probabilities. Summing the branch probabilities creates a distribution.


When we plot this distribution, which we call the COPT, or capacity outage probability table, we need to interpret it this way: (note - the points below are not from the above table)





The binary tree MW and probabilities are shown mapped to a cumulative distribution.




Now we can easily add one more generator to the left of the binary tree and this causes two new trees to be formed and two new LOLP curves to be formed.



Sum the Pr of these two curves to create an 'after' Pr curve.





$$[F(x)^+ = (1 - FOR_k) \cdot F(x)^- + FOR_k \cdot F(x - C_k)^-] \quad \forall x = 0, x_{max}$$


Once the COPT is created, the indices LOLE (loss of load expectation), LOLH (loss of load hours), and EUE (expected unserved energy) are calculated directly from the LOLPs:

$$\text{LOLE} = \sum \text{daily maximum LOLPs for a year (days/year)}$$

$$\text{LOLH} = \sum \text{hourly LOLPs for a year (hours/year)}$$

$$\text{EUE} = \sum \text{integral of all LOLP} \times \text{MW from net MW} \\ \text{demand down to 0 MW every hour (MWh)}$$

IEEE 1979 RTS (Reliability Test System)



COPT Array Size Is Small and Execution Speed Is High

- The 1979 RTS tree was large; 32 generators $2^{32} > 4$ billion states.
- The 1979 RTS COPT size in RTS3 “exact” LOLPs is 2652 numbers.
- COPT saves space by use of integer 1 or .1 MW grid increments.
- The 1996 RTS tree was larger; 96 generators $2^{96} > 10^{28}$ states.
- The 1996 RTS COPT size in RTS3 “exact” LOLPs is 5156 numbers.
- The ERCOT system with 380 generators COPT is 16296 numbers.
- The CAISO system with 530 generators COPT is 26961 numbers.
- Creation of COPT uses linear arrays which are efficiently executed.
- Once COPT is created, LOLP becomes a simple lookup (no math).

- RTS3 generator data looks like:

```

PMAX ,RM%, FOR, DER,DMW, BU#,GENERATORNAM,TP,
:      :      :      :      :      :      :
155.,100,.040,.000, 0., 115,ARTHUR_Coal3,ST,
155.,100,.040,.000, 0., 116,ASSER__Coal1,ST,
355.,100,.033,.000, 0., 118,ASTOR__NG__1,CC,
400.,100,.120,.000, 0., 121,ATLEE__Nucl1,NU,
155.,100,.040,.000, 0., 123,AUSTEN_Coal2,ST,
350.,100,.080,.000, 0., 123,AUSTEN_Coal3,ST,
:      :      :      :      :      :

```

- RTS3 hourly data looks like:

```

YYYYMMDDHH,D, DEMAND, HYDRO, WIND, SOLAR, SOLARR(rooftop),
2020010101,4,0.40740,0.1842,0.850074,0.000000,0.000000,
2020010102,4,0.39809,0.1990,0.909606,0.000000,0.000000,
2020010103,4,0.39639,0.1638,0.843176,0.000000,0.000000,
2020010104,4,0.39852,0.1678,0.819610,0.000000,0.000000,
2020010105,4,0.41540,0.1626,0.796922,0.000000,0.000000,
2020010106,4,0.44828,0.1410,0.773835,0.000000,0.000000,
2020010107,4,0.48201,0.1506,0.681646,0.000000,0.000000,
2020010108,4,0.48668,0.2886,0.541848,0.416726,0.145686,
2020010109,4,0.48862,0.2514,0.464612,0.600515,0.365249,
2020010110,4,0.49224,0.3386,0.309143,0.671727,0.531686,
2020010111,4,0.49111,0.3506,0.169146,0.703056,0.635784,

```

- RTS3 program results versus the 1986 paper results.

1979 Base Case = 2850 MW Load,
3405 MW Total Generation, LFU=0

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	1.36886 d/y	1.368863 d/y
LOLH =	9.39418 h/y	9.394175 h/y
EUE =	1176 MWh	1176 MWh

1979 Base Case with 3 State Gens

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	0.88258 d/y	0.882573 d/y

1979 Base Case with 2% LFU

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	1.45110 d/y	1.451109 d/y

1979 Base Case with 10% LFU

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	3.99763 d/y	3.986904 d/y

1979 Base Case, Demand = 2394 MW

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	0.04756 d/y	0.047559 d/y

1979 Base Case, Demand = 3135 MW

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	6.68051 d/y	6.680512 d/y

1979 Base Case with 5% LFU

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	1.91130 d/y	1.911295 d/y

1979 Base Case with 15% LFU

	<u>1986 Paper</u>	<u>RTS3 Program</u>
LOLE =	9.50630 d/y	8.205766 d/y

- RTS3 program results for two RTS 2020 cases, both with LOLE = 0.1 d/y.

2020 RTS has three areas that individually peak at 2850 MW. The coincident peak demand is 8191.8 MW. The cases have 8076 MW conventional generation and 1000 MW of hydro. In the first 2020 Model RTS case the LFU = 0%, wind is 810 MW, and 500 MW solar is split between rooftop and tracking PV.

Indices for a 0.00% LFU:

LOLE	=	0.100005 d/y
LOLH	=	0.236470 h/y
EUE MWh	=	37. MWh
EUE ppm	=	0.98 pu ppm
LOLP>.0004=		117 hrs

A second RTS case is run that utilizes VER capacities of 2508 MW wind and 2716 MW solar. The LFU is increased to 7.68% to achieve LOLE = 0.1 d/y.

Indices for a 7.68% LFU:

LOLE	=	0.100048 d/y
LOLH	=	0.282378 h/y
EUE MWh	=	58. MWh
EUE ppm	=	1.54 pu ppm
LOLP>.0004=		168 hrs

GDATA File: G2020.TXT <- NREL 2020 RTS generator data with wind and solar on Github
 HDATA File: H2020.txt <- NREL 2020 RTS hourly file with wind and solar on Github

2020 IEEE RTS 8192 MW load 8076 MW conventional generation with 1000 MW hydro 810 MW wind 500 MW solar.
 2020 IEEE RTS hourly demand wind hydro and solar profiles created from <https://github.com/GridMod/RTS-GMLC>

MAX GENR = 8076 MW
 VARBL RES = 1043 MW
 GENR+VRES = 9119 MW
 MAX COPT = 4524 (90000 MAX)

2020 RESULTS:

PERIOD = 8784 HOURS
 PEAK DEMD = 8191.800 MW
 RESERVE = 11.3 %
 LOAD ENGY = 37656. GWh
 LOAD FACT = 52.331 %
 PEAK NETD = 7017.141 MW (DEMD-VR)
 VR E USED = 7457. GWh
 VR E LOST = 0. GWh
 Indices for a 0.00% LFU:
 LOLE (AM) = 0.000000 d/y
 LOLE (PM) = 0.100005 d/y
 LOLE = 0.100005 d/y
 LOLEV ** = 0.100005 events/y
 LOLEMW = 156. MW
 LOLH = 0.236470 h/y
 LOLH/event = 2.364584 h/event
 EUE MWh = 37. MWh
 EUE ppm = 0.98 pu ppm
 EUE % = 0.000098 %
 LOLP>1.E-4 = 117 hrs

Variable Resource Capacity Credits
 Max Net Demand hrs for LOLP>1.E-4:

76.6% 9.3% 43.1% 37.6%

** LOLE measures events/24 hrs
 LOLEV measures events/12 hrs

2020 NREL RTS3 Update Adding Wind and Solar NREL Project Overview:

<https://github.com/GridMod/RTS-GMLC/blob/master/RTS-GMLC.pdf>

2020 NREL RTS3 program code and data:

https://github.com/GridMod/RTS-GMLC/tree/master/RTS_Data/FormattedData/RELIABILITY

RTS3 program (with a new storage model):

<http://egpreston.com/RTS3S.zip>

- RTS3 automatically finds a demand to achieve a desired LOLE:

```

GENERATOR DATA FILE NAME:  G20
TARGET LOLE (OR RETURN):   1.0 (desired LOLE)
RTS3 is executing...
calculating the COPT
LOLE d/y  MW Demand      Upper MW      Lower MW
30.199082  9999.000      9999.000      0.000000
0.000000   4999.500      9999.000      4999.500
0.001158   7499.250      9999.000      7499.250
1.397416   8749.125      8749.125      7499.250
0.068313   8124.188      8749.125      8124.188
0.349934   8436.656      8749.125      8436.656
0.747597   8592.891      8749.125      8592.891
1.021407   8671.008      8671.008      8592.891
0.869544   8631.949      8671.008      8631.949
0.942400   8651.479      8671.008      8651.479
0.980704   8661.243      8671.008      8661.243
1.002307   8666.125      8666.125      8661.243
0.989530   8663.684      8666.125      8663.684
0.994424   8664.905      8666.125      8664.905
0.995016   8665.515      8666.125      8665.515
1.000506   8665.820      8665.820      8665.515
1.000449   8665.668      8665.668      8665.515
0.995484   8665.591      8665.668      8665.591
0.995484   8665.630      8665.668      8665.630
0.995484   8665.649      8665.668      8665.649
0.995484   8665.658      8665.668      8665.658
1.000449   8665.663      8665.663      8665.658
1.000449   8665.663      8665.663      8665.658 < finished in 8 sec
LOLE~=1    8198.8 was the LOLE = 0.1 d/y load.

```